

# The impact of flue gas desulphurisation on lime and limestone marketing

by

Robert C. Freas,  
Chief Geologist

Dravo Lime Company  
Pittsburgh, Pennsylvania, USA

---

## Abstract

Sulphur dioxide removal, or flue gas desulphurisation (FGD), has become a major concern to coal-fired electric generating stations and industrial boiler operators in the United States. Since 1971 there has been an increasing emphasis on air quality, with the latest and most stringent regulations having now been promulgated under the US Environmental Protection Agency's 1977 Clean Air Act Amendments. As a result of these air quality requirements, a variety of FGD systems are now being developed. Almost all of these systems utilise lime or limestone as the reagent material for sulphur dioxide removal, and thus flue gas desulphurisation would appear to be a promising new market for the lime and/or the limestone industry.

Because of the volume of coal burned by the electric power generating industry and the degree of air quality control which is being required, FGD has already become a major new market for lime and limestone. As the lime and limestone industry looks ahead to future expansion and facilities development, the demands of the FGD market deserve critical examination. Thus far, product quality and costs have been key items; with changing technology, however, volume requirements and specifications have become somewhat of a moving target and are still changing.

This paper briefly examines the type of FGD systems that have been successfully employed to date and those systems currently being brought into commercial utilisation. The potential application of each of these systems and their reagent requirements are then discussed both in terms of quality specifications and overall anticipated volume requirements. Reagent materials considered include lime, limestone, dolomite and magnesium-enhanced lime and limestone.

Questions relating to the future demand for lime and limestone for use in sulphur dioxide removal systems are discussed in light of the impact this new market will have on existing sources and producers. Where will the lime/limestone be needed and where will it come from? Is there adequate lime production capacity available to meet the potential 1980-2000 environmental demand, or is this market only a mirage? Are there adequate reserves available to meet the requisite quality requirements? Can quality be sacrificed to achieve transportation cost savings? Will the lime/limestone producer have to change his marketing approach in order to achieve a share of the market?

---

## Discussion

### Federal Clean Air Requirements

In 1971 the United States Environmental Protection Agency (EPA) implemented the Clean Air Act with the promulgation of a set of air pollution control regulations. These requirements became known as the New Source Performance Standards and had the net effect of requiring all coal-fired electric generating stations starting construction after 1971 but prior to September 1978 to limit their SO<sub>2</sub> emissions to not more than 1.2 lb/million BTU. In essence this left the utilities with the choice of either burning low sulphur "compliance coal", or using medium to high sulphur coals with scrubbers.

As of September 1979, 56 coal-fired power generating units were equipped with operating flue-gas desulphurisation (FGD) systems.<sup>1</sup> These units represent a total controlled capacity of 21,104 megawatts (MW), or 9.2 percent of the

US coal-fired generating capacity. However, as the impact of the 1971 Clean Air Act began to be felt and as FGD technology expanded, federal officials recognised that certain revisions to the Clean Air Act were necessary. As a result, in August 1977 amendments to the Clean Air Act were passed by the US Congress, and in May 1979 the EPA issued a revised set of New Source Performance Standards.

The revised standards provide the utilities with a broad range of options in the selection of the coal they will use and the manner in which sulphur removal will be accomplished. However, all coals will be subject to sulphur removal requirements, no matter what their original sulphur levels may be, as there is no specific floor for sulphur dioxide emissions. The regulations classify coals into three categories, each with a different level of required SO<sub>2</sub> reduction. Thus, the concept of "compliance coal" has been effectively eliminated.

### Impact on Coal Utilisation

In addressing the market potential for lime and limestone reagent materials for SO<sub>2</sub> removal, it is necessary to have some understanding of what coals are likely to be burned and where. Since there is considerable variation in coal quality from one region of the USA to another the specific SO<sub>2</sub> removal options most likely to be considered by a utility will vary with geographic location. Thus the more probable options which will be considered are as follows:<sup>2</sup>

(a) Western utilities will utilise western coals originating in Colorado, Montana, Utah, and Wyoming. Most of these coals can be used with the 70% dry scrubbing option, which is discussed later, although several of the plants are expected to opt for wet scrubbing. (b) In the southwest the utilities have the option of using either western bituminous or sub-bituminous coals, or lignites. Sulphur content in these lower grade coals tends to vary, and this combined with the lower heating values means that the probable options available would be dry scrubbing, dry scrubbing combined with derating boiler capacity as sulphur levels increased, or wet scrubbing. If and when fluidised-bed combustion becomes a viable alternative for plus 250 megawatt (MW) units, this is the area in which it may first be employed. (c) Southern utilities have traditionally used Appalachian coals which have low to high sulphur values depending upon the particular seam utilised. However, southwestern lignites and western low sulphur coal have been selected by some utilities in this area. (d) Mid-western utilities also have a wide range of fuel alternatives. Low sulphur western and east Kentucky coal is available as well as the medium to high sulphur coals of western Kentucky, Illinois, Indiana, and Ohio. Sulphur removal in this region will most likely be achieved via wet scrubbing or a combination of wet scrubbing and coal washing. (e) In the eastern states the transportation costs associated with the use of low sulphur coals tend to eliminate them from consideration for most utilities. Therefore, medium sulphur Pennsylvania coal is expected to be the primary source of fuel for any new plants. Thus, wet scrubbing is expected to be the primary mode of sulphur removal, although a greater degree of technical innovation may be seen in the eastern states. Coal-oil mixtures, blended coals, and solvent refined coals (SRC) may be considered.

### Scrubber Technology

Of the existing generating units with commercial FGD systems over ninety percent employ wet calcium-based lime/limestone processes. These systems include lime,

"Thiosorbic"<sup>®</sup> lime, carbide lime, lime/alkaline fly ash limestone, and limestone/alkaline fly ash. The remainder include magnesium oxide, sodium carbonate, and the Wellman Lord processes. Of these, the limestone and "Thiosorbic" lime systems are employed on the most units generating the greatest number of megawatts.

While there has been much discussion about the reliability and efficiency of wet scrubbing, it has been demonstrated that wet scrubbing is a viable technology and that 90 percent plus efficiency in sulphur removal can be achieved.<sup>3</sup> With these kinds of results and the consistent improvements in system reliability and efficiency being achieved through increased operator experience, wet scrubbing is being selected by an increasing number of utilities as the preferred method of sulphur removal. Further, despite initial differences in reagent costs, lime and limestone, it has been demonstrated that lime and "Thiosorbic" lime systems continue to be technically and economically competitive alternatives available to the utility industry.<sup>4</sup>

But what about alternative technology? Over the last decade a tremendous effort has been put forth to find alternative methods of sulphur removal. Of these, dry scrubbing, which uses lime or sodium as a scrubbing reagent, has already found commercial acceptance in the northern plains states where it has been selected by Basin Electric Power Cooperative.<sup>5</sup> Initial results indicate that this process will be particularly adaptable to those units using low sulphur western coal and requiring only 70 to 85 percent removal. Further, due to the generally better availability of lime is emerging as the preferred reagent material. However, at this point in the development of the dry scrubber, it does not appear that it will be suitable for medium and high sulphur coals due to the higher removal efficiencies required for these coals. Also, the waste products are by nature dry and can be quite high in alkalinity, thus raising questions concerning the disposal of these materials. This is particularly important in areas of high rainfall where the erosiveness and solubility of these wastes could contribute to their introduction into surface and/or ground water.

A second technology which has received a great deal of publicity is that of fluidised-bed combustion (FBC). This process utilises dry limestone and has been extensively studied by Westinghouse and others.<sup>6,7</sup> One of the primary advantages of fluidised-bed combustion is that it can utilise a broader quality range of limestones than most of the

<sup>®</sup> - Registered trademark of Dravo Corporation

Table 1—Quality characteristics of coal and estimated annual lime/limestone consumption per megawatt

Source of Coal	Btu/Lb.	%S	Required SO <sub>2</sub> Removal	Lime (mt) Yr . MW	Limestone (mt) Yr . MW
East Kentucky	11,796	1.26	71.9	38	78
West Kentucky, West Virginia	10,996	3.59	90.0	147	299
Illinois	10,775	2.92	88.9	121	245
Texas	6,601	0.66	70.0	35	72
Colorado	10,925	0.49	70.0	15	32
New Mexico, Arizona	9,996	0.54	70.0	19	38
Wyoming	9,037	0.50	70.0	19	39
Pennsylvania	12,200	2.22	83.5	76	154

other sulphur removal systems.<sup>8</sup> Unfortunately, as of this date the FBC has been used only on small industrial boilers and in pilot plants. As yet the system has not been scaled up, and due to the capital cost and complexity of the material handling and feed systems may never be employed on larger generating units with 250 MW plus capacities.

Other sulphur removal processes include solvent-refined coal cleaning, chemical coal cleaning, and coal gasification. In addition coal-oil mixtures, blended coals, and coal washing via standard coal preparation technology are being considered in an attempt to reduce the sulphur levels prior to firing. Nevertheless, wet lime/limestone scrubbing is expected to predominate in reducing SO<sub>2</sub> emission levels over the next ten to fifteen years.

### Reagent Requirements

If wet lime/limestone scrubbing is expected to be used by new generating units coming on line between 1980 and 1995, and if lime will be employed by the dry scrubbers, what size market does this actually represent? *Table 1* shows the annual estimated lime or limestone consumption per megawatt which would be anticipated with a variety of different coals. These estimates are based upon a 65% load factor, 10,000 BTU/kilowatt hour, stoichiometry of 1.05 for lime and 1.2 for limestone, and a minimum 95% CaO or CaCO<sub>3</sub>. Taking the information in *Table 1* a step further, assume a 600 MW generating station using eastern Kentucky coal. From the table it is noted that the average eastern Kentucky steam coal would require 38 metric tons (42 short tons) of lime or 78 metric tons (86 st) of limestone per megawatt per year to achieve the required sulphur removal levels. Therefore, a 600 MW unit would require 22,800 metric tons (25,200 st) of lime or 46,800 metric tons (51,600 st) of limestone per year.

The size of the actual potential market is, however, difficult to define specifically. For instance, fifteen selected units in the Ohio River Valley, representing a total generating capacity of 8542 megawatts, are planned to be brought on line between 1982 and 1990. These fifteen units will burn an average 3.4 percent sulphur coal requiring 90 percent plus removal efficiency. Thus, these selected units alone represent a potential annual market of 1,156,062 tonnes (1,274,600 st) of lime or 2,427,730 tonnes (2,676,660 st) of limestone. On the other hand, these same 15 units, located in the West and burning Colorado-Wyoming-Utah type coals, would represent an annual market of only 128,130 tonnes (145,214 st) of lime or 273,344 tonnes (298,970 st) of limestone. While this is an extreme example it does demonstrate the impact on lime/limestone market predictions which the various options available to a utility can have.

Earlier it was noted that 56 coal-fired generating units were equipped with operating FGD systems. In addition to these units there are 42 more which are under construction, 19 for which contracts have been awarded, 18 planned and are evaluating system alternatives, and 26 in the early phases of study.<sup>9</sup> This is a total of 161 units representing an overall capacity of 76,335 MW, or over three times the operational capacity of existing generating units with FGD systems. Of these 161 units 61 fall into the category of being under construction or having had a contract awarded, and thus represent a relatively near-term pending market. *Table 2* summarises the anticipated coal quality which will be used in these new units, and attempts to estimate the lime/limestone market which these units represent. While the lime and limestone requirements are estimates only

they are believed to be reasonable based upon reagent usage in operational FGD systems.

The estimated figures included in *Table 2* make up only part of the market forecast. Long-range estimates of the impact of FGD system requirements on lime and limestone demand are complicated by the fact that 44 of the 16 units mentioned earlier have yet to make an FGD system selection. Assuming that these 44 units, representing an additional 26,113 MW capacity, utilise approximately the same relative lime and limestone quantities, the total projected new requirements to 1990 would be 1,726,04 metric tons (1,902,962 st) of lime/year and 2,952,19 metric tons (3,254,797 st) limestone/year.

It must be noted that in preparing an estimate of future FGD system demand there are a number of recent political and economical events which may significantly impact utility expansion plans. For one, since the Three Mile Island incident in 1979 there has been a noticeable slow down in planning for nuclear power generating facilities. It is possible that as a result of escalating costs, major permitting questions, etc., that utilities which had nuclear power plants on the drawing boards could switch to coal fired units. Additionally, with the increase cost of petroleum products and transportation combined with the revised New Source Performance Standards there may be less incentive for the utilities to opt for low sulphur western coals. Again there may be revisions in plans with the consequence being that higher sulphur coals could be in greater demand. Two additional considerations which are not included in this market projection are the impacts of retrofitting existing boilers with FGD equipment, and coal conversion. As yet it is not clear how many existing units may be required to retrofit, and if so required will the utilities elect to deactivate these plants? Also, there is considerable impetus at the moment to require oil and gas fired units to convert to coal, particularly in the northeast. There is a distinct possibility that an incentive to conversion may be to not require scrubbing, or if required to reduce the attainment levels. Finally, the anti-coal attitude of the Pacific coast states are gradually changing, and coal-fired plants are now anticipated for California, Oregon and Washington. The net result of all of this is that the demand for lime and limestone reagent materials for FGD systems could increase beyond the figures presented herein.

One additional area which has not been discussed is that of the smaller industrial boilers. Sulphur dioxide removal requirements are already being implemented for coal-fire industrial boilers in several parts of the country. However while many of these boilers will have scrubbers it is anticipated that this is the market where fluidised-bed combustion will have its greatest impact. Since these boilers can utilise a wide range of limestones and generally require 25,000 tons or less of stone per year, it is expected that the requirements will normally be supplied by the local quarryman or supplier with the most reasonable delivered price.

### Market Location

Assuming that the projected expansions take place the next question is where will these plants be located. Two of the major items in locating a power plant are a source of cooling water and transportation. *Figure 1* shows the location of the major new power plants in the USA. From this it can be seen that the majority of the new units will be in the eastern half of the nation and that many of them are on or near navigable water.

In looking at the locations of these plants, relative to

Table 2—Summary of new FGD systems, anticipated coal quality, and potential lime/limestone requirements

FGD Process	Capacity (MW)	Coal Quality		Estimated Reagent Requirements/Year*	
		Heating Value (BTU)	Sulphur	Lime (mt)	Limestone (mt)
Dual Alkali	None				
Lime	1,854	9500–12500	0.5–1.0	67,500	
	1,120	10500–11500	2.0–3.0	117,600	
	3,690	11000–12200	3.0–4.7	542,430	
Limestone	1,166	6500– 7500	1.2–1.8		169,070
	5,439	7500–10000	0.3–0.9		212,121
	1,818	10500–12000	1.2–1.8		141,804
	2,413	10250–12500	2.0–3.7		395,732
	2,338	9500–11000	3.0–5.5		572,810
Lime/Alkaline Fly Ash	3,097	6250– 8500	0.6–0.8	54,198	
Limestone/Alkaline Fly Ash	None				
Lime/Spray Drying	1,048	6000– 7500	0.4–0.7	36,680	
Others	2,682			53,640	
Totals	26,665			872,048 metric tons	1,491,537 metric tons

\*Estimated reagent requirements are based upon weighted average coal quality and SO<sub>2</sub> removal requirements.

supplying their potential reagent materials, several points clearly emerge. One of these being the necessity to take advantage of cheap transportation. A coal-fired generating plant is set up to handle large bulk shipments of coal, usually by either rail or barge. Current studies show that coal can be moved via waterway transportation at the rate of 37 metric ton-kilometers per litre (250 st-miles per gallon) compared to 29.6 metric ton-kilometers per litre (200 st-miles per gallon) for rail and 8.7 metric ton-kilometers per litre (58 st-miles per gallon).<sup>10</sup> This cost incentive for barge movement leads to projections that coal shipments on the inland waterways will double by the year 2000. These same transportation cost savings are available to the lime/limestone supplier as well.

In view of the volume of lime and limestone which will be used in FGD systems the lime/limestone producer should examine the transportation alternatives available to him. Many producers are already aware of the commercial advantages and importance of cheap transportation, as evidenced by the number of quarries and lime plants already located on the Ohio and Mississippi Rivers. Those producers who are already utilising rail and/or barge transportation in the marketing of their products are probably in the best position to take advantage of the FGD market. However, with the incentive of the additional tonnage potential other operators may be able to justify rail-sidings into their plant or partial relocation of their quarry operations to better facilitate barge or rail load-out.

A second item noted from Figure 1 is the degree of scatter seen in the location of new generating stations in the Rocky Mountain and far-western states. Many of these plants are mine-mouth, or in other words located on coal deposits. Further, since these are basically low sulphur coals, dry lime scrubbing and lime/alkaline fly ash are expected to play a major role in FGD removal here. This in turn would indicate that the per unit annual lime consumption will be modest. This fact combined with the distances involved means that the lime supplier will have to take advantage of any transportation cost savings he can. Also, he will have to coordinate his total marketing effort as it is unlikely that he will be able to rely on this market alone to sustain his operations.

The remainder of the plants shown in Figure 1 are somewhat more randomly scattered and will very likely be supplied on a somewhat more localised basis. This same is also true of the smaller industrial boilers fitted with FGD systems. Nevertheless, as with any of these potential lime/limestone customers the key to marketing success will be found in the delivered cost/ton, reliability, and the ability to meet the requisite quality specification.

#### FGD lime/limestone specifications

Lime specifications for wet scrubbing are concerned with chemical quality, reactivity, and insoluble residues, much the same as most other lime users. The basic requirements under this specification are generally total oxides 90%





disposal. The coal-fired generating station fitted with an FGD system will produce voluminous quantities of fly ash and scrubber sludges. Depending upon the location and environmental constraints, the quarry may be able to reduce its overall transportation costs by backhauling fly ash and stabilised scrubber sludges for disposal in abandoned portions of the quarry. This would be done on a fixed price per ton disposal fee and could represent an additional source of revenue to the quarry.

The lime industry is in a somewhat different position relative to FGD than is limestone. Total lime production in the United States hovers around 18 million metric tons (20 million short tons) per year of which almost seventy-five percent is sold on the open market. Thus the potential new business represented by sulphur dioxide removal could equal ten percent or more of current production. Unfortunately this potential is very much up in the air as to whether it really exists or not. Scrubber technology is changing and there are many unanswered questions still remaining which will ultimately influence the utilities selection of equipment. Recently a great deal of emphasis has been placed on the cost differential between lime and limestone. However, the lime industry can overcome at least part of this differential by thoroughly understanding the total cost of scrubbing. In other words, a cost analysis approach to marketing, including capital, financing, operating, and disposal cost considerations, must be taken if the lime producer is to be successful. Additionally, the supplier may want to consider providing technical support services to his customers as a further incentive.

### Summary of marketing considerations

From the foregoing discussion it is clear that there are a number of factors at work which will influence the degree to which FGD reagent supply does in fact materialise as a major new market. The lime/limestone producer can enhance his ability to realise the potential of at least part of this market if he includes certain basic elements into his marketing strategy.

1. First the producer must have a basic understanding of his potential customers' needs and to have some understanding of scrubbing. In order to assess the size of the market available to his operations he must know the anticipated timing for the new plant or retrofitted system, the type of coal which will be used, and the scrubbing process to be employed. The element of utility timing may be critical since rarely has the published plant start-up date been the same as the actual start-up date. Public hearings, permit delays, reduced consumer demand, etc., can lead to a plant actually coming on-line two years or more behind original schedules. Therefore, the reagent supplier will have to consider the impact these delays could have on his own expansion plans, capital commitments, product mix, etc. Also, the coal quality and FGD process must be known for each unit in order to accurately forecast material volumes.
2. Transportation is a major element in the delivered cost of both lime and limestone. If the quarryman is not already familiar with transportation alternatives and the impact on pricing this could have on any given customer, he should bring himself up to date. This does not mean a top-of-the-head estimate, but to acquire quotations for the actual truck, rail, or barge move anticipated. The advisability of installing a rail siding, additional car

storage, different loading equipment, storage silos, or whatever equipment might be germane to his operations should be investigated. He may also want to investigate the receiving facilities of the utility, and may want to recommend the inclusion of additional storage capacity at the plant.

3. The operation of a utility is an all-year function, and unlike the quarry the power plant cannot shut down for bad weather. Thus, during the assessment of transportation alternatives and facilities the quarryman will have to investigate the measures he may have to take in order to assure the FGD system of a reliable supply of reagent materials. Again this may include additional storage capacity at either the quarry/lime plant or the utility, or at both points.
4. Quality control will be a necessary element of production in supplying the utilities' lime and limestone needs. As noted earlier this is something with which the lime industry is familiar. The limestone producer will, however, have to be able to supply calcium and inert values as a minimum, along with material gradations. Additionally, if the quarry does not already have a detailed geologic report on its deposit, including chemical analysis, it should proceed to obtain one. Only with a thorough understanding of quality variations in their reserves can the quarry plan its operations, particularly if selective quarrying is necessary.
5. Since the supply of scrubber reagent materials can require a substantial capital outlay by the producer in order to supply this lime/limestone, the producer may want to enter into a long-term contract for supply with the utility. Coal contracts with the utilities are commonly written for five year periods, and it is reasonable to expect that similar commitments could be obtained for lime/limestone. This type of arrangement may be new to the limestone operation, but it could be most helpful to him in planning both his quarry/mine operations and overall market objectives. Also it would provide a basis for planning any capital expenditures which may have to be made. The inclusion within the contract of an anticipated monthly tonnage schedule might also help to avoid some of the difficulties which are often associated with meeting wide swings in volume demands. These swings will occur and result from changing consumer demand due to heating, air conditioning, etc.
6. Backhauling and disposal of waste products should not be overlooked as a possible adjunct to FGD lime limestone arrangements. This could be a profitable business, and transportation costs on the stone could possibly be adjusted to provide more competitive pricing of delivered stone products. If this is attempted the quarry operator must be sure he is familiar with all the applicable environmental laws and that his disposal fees are adequate to cover all of the costs of compliance with the laws. It makes little sense to make a profit on stone and then lose it all on a disposal operation.
7. There are a variety of technical support services which the lime/limestone operator may want to consider providing to his customers. These services could range from material handling and grinding at the utility to more sophisticated operations such as performing compliance testing. Again, however, these services should be looked upon as a part of the business and their costs covered through product pricing or an established fee

schedule. The availability of these services may help secure the business and could enhance the operator's own knowledge of the FGD business. This in turn could have positive consequences as additional FGD systems come on-line.

8. The last item relates to the first. The producer should learn the language of sulphur dioxide removal. He should be familiar with FGD systems and the total cost per ton of sulphur removed, including all of the various cost elements of scrubbing and scrubber waste disposal. Only when he has a firm grip on these costs can he prepare a detailed cost comparison between his product and that of his competitors. To this end he may want to have his product tested for suitability in a scrubber system. The results of such testing could help him in the marketing of his product, or could possibly even indicate this is the wrong application for his material.

### Conclusions

Flue-gas desulphurisation does represent a very real potential market. The size of the market, however, and the relative demand for lime and limestone still remain somewhat of a question. Early projections which forecast a market for 20 to 40 million tons of limestone per year appear now to have been overly optimistic. The market for limestone is expected to reach 3.0 to 3.5 million metric tons per year by the year 1990. This should prove a very nice addition to the tonnage stone produced at those operations situated such that they can take advantage of this new potential. To the limestone producer it means he may have to make some adjustments to his marketing approach and possibly within his quarry/mine operations. These changes should not be difficult to accomplish and could have a very positive impact on his total sales effort.

The projected lime market of 1.7 to 2.0 metric tons is somewhat more elusive than the limestone predictions. Technological developments over the next five years certainly will bear strongly upon the degree to which this market is realised. Several expansions and/or new lime plants have been announced for the early 1980s, but if the market approaches current predictions, additional lime production capacity will still have to be brought on line. Dry lime scrubbing is expected to be a major factor in the western states and should represent a worthwhile potential in this area. Wet scrubbing could predominate in the northeast because of the reduced volume of waste products and the relative availability of lime vs. limestone. The remainder of the market is very much in question, but with an aggressive and knowledgeable marketing effort the lime producers should be able to secure a reasonable share of the FGD business.

### References

1. Smith, M. and Melia, M., 1979, EPA Utility FGD Survey, July-September 1979, Interagency Energy/Environment R&D Program Report, US Environmental Protection Agency, PEDCO Environmental Inc., EPA 600/7-79-022f, October.
2. Allen, Z. and Kaslow, D.A., 1979, "Effects of the New Clean Air Regs", Coal Age, August, pp. 119-125.
3. Murphy, J.T., 1979; "Start-up Experience With Lime Scrubbing At Pleasants Power Station", paper 79-31.4, Air Pollution Control Association, 72nd Annual Meeting, Cincinnati, Ohio, June, 14 pp.
4. Stowe, D.H., Henzel, D.S., and Hoffman, D.C. 1979, "The FGD Reagent Dilemma-Lime, Limestone, or Thiosorbic Lime", Proceedings: Symposium on Flue Gas Desulphurisation, Las Vegas, Nevada, March, Vol. II, EPA 600/7-79-1676, 18 pp.
5. Jenssen, K.E. and Eriksen, R.L., 1979; "Basin Electric's Involvement With Dry Flue Gas Desulfurisation", Proceedings: Symposium on Flue Gas Desulfurisation-Las Vegas, Nevada, March, Vol. II, EPA 600/7-79-1676, 24 pp.
6. US Environmental Protection Agency, 1973; "Proceedings of Third International Conference on Fluidized Bed Combustion", US Department of Commerce, National Technical Information Service, PB-231-977.
7. Jonke, A., Vogel, G., Johnson, I., Lee, S., Lenc, J., Lesariet, A., Montagna, J., Nunes, F., Shearer, J., Snyder, R., Smith, G., Swift, W., Teats, F., Turner, C., and Wilson, J., 1977; "Supportive Studies in Fluidised Bed Combustion", Argonne National Lab, III, National Technical Information Service, PB-276-974, 193 pp.
8. O'Neill, E.P. and Keairns, D.L., 1975; "Selection of Calcium-Based Sorbents For High-Temperature Fossil Fuel Desulfurisation", 80th American Institute Chemical Engineers National Meeting, Boston, 26 pp.
9. op cit., Smith and Melia, 1979, p viii.
10. \_\_\_\_\_, Coal Barge Shipments to Double by 2000", Coal Age, January 1980, pp 29-30.
11. Personal contact with D. Stewart, Electric Power Research Institute, Menlo Park, California.
12. Borgwardt, R.H. and Campbell, T.J., 1979; "Limestone Type-And-Grind Tests at EPA/IERL-RTP", presented at 5th Shawnee Industry Briefing Conference, Raleigh, North Carolina, December, 26 pp.
13. Reed, A.H., 1977; "Stone", Preprint from the 1977 US Department of the Interior, Bureau of Mines Minerals Yearbook, Washington, DC, 28 pp.